Level 2 Electric Vehicle Charger Service Load Calculator

INSTRUCTIONS: Review the list of electrical loads in the table below and check all that exist in your home (don't forget to include the proposed Level 2 charger). For each item checked, fill in the corresponding "Watts Used" (refer to the "Typical Usage" column for wattage information). Add up all of the numbers that are written in the "Watts Used" column and write that number in the "TOTAL WATTS USED" box at the bottom of the table. Then go to the next page to determine if your existing electric service will accommodate the new loads.

(Loads shown are rough estimates; actual loads may vary. For a more precise analysis, use the nameplate ratings for appliances and other loads and consult with a trained electrical professional.)

Check all Applicable Loads (✓)	Description of Load	Typical Usage	Watts Used
	GENERAL LIGHTING AND RECEPTAC	LE OUTLET CIRCUITS	
	Multiply the square footage of house x 3	3 watts/sq. ft.	
	KITCHEN CIRCUI	TS	
	Kitchen circuits	3,000 watts	
	Electric oven	2,000 watts	
	Electric stove top	5,000 watts	
	Microwave	1,500 watts	
	Garbage disposal under kitchen sink	1,000 watts	
	Automatic dish washer	3,500 watts	
	Garbage compactor	1,000 watts	
	Instantaneous hot water at sink	1,500 watts	
	LAUNDRY CIRCUI	TS	
	Laundry circuit	1,500 watts	
	Electric clothes dryer	4,500 watts	
	HEATING AND AIR CONDITIO	NING CIRCUITS	
	Central heating and air conditioning	6,000 watts	
	Window mounted air conditioning	1,000 watts	
	Whole-house or attic fan	500 watts	
	Central electric furnace	8,000 watts	
	Evaporative cooler	500 watts	
	OTHER ELECTRICAL L	.OADS	
	Electric water heater (storage type)	4,000 watts	
	Electric tankless water heater	15,000 watts	
	Swimming pool or spa	3,500 watts	
	Other (describe)		
	Other (describe)		
	Other (describe)		
	ELECTRIC VEHICLE CHARG	ER CIRCUIT	
	Level 2 electric vehicle charger wattage rati	ng	
	-	TOTAL WATTS USED	

INSTRUCTIONS: Using the "TOTAL WATTS USED" number from the previous page, check the appropriate line in column 1 and follow that line across to determine the minimum required size of the electrical service panel shown in column 3. In column 4, write in the size of your existing service panel (main breaker size). If your existing service panel (column 4) is smaller than the minimum required size of the existing service (column 3), then you will need to install a new upgraded electrical service panel to handle the added electrical load from the proposed Level 2 charger.

The table below is based on CEC 220.83(A), 230.42 and Annex D.

1	2	3	4
Check the appropriate line (✓)	Total Watts Used (from previous page)	Minimum Required Size of Existing 240-Volt Electrical Service Panel (Main Service Breaker Size)	Identify the Size of Your Existing Main Service Breaker (Amps)*
	up to 48,000	100 amps	
	48,001 to 63,000	125 amps	
	63,001 to 78,000	150 amps	
	78,001 to 108,000	200 amps	
	108,001 to 123,000	225 amps	

*Note that the size of your <u>existing</u> service (column 4) MUST be <u>equal to or larger than</u> the Minimum <u>Required</u> Size (column 3) or a new larger electrical service panel will need to be installed in order to satisfy the electrical load demand of the EV charger.

STATEMENT OF COMPLIANCE

By my signature, I attest that the information provided is true and accurate.

JobAddress:

(Print job address)

Signature:

123 Office of Planning & Research – State of California

(Signature of applicant)

In addition to this document, you will also need to provide a copy of the manufacturer's installation literature and specifications for the Level 2 charger you are installing.

Note: This is a <u>voluntary</u> compliance alternative and you may wish to hire a qualified individual or company to perform a thorough evaluation of your electrical service capacity in lieu of this alternative methodology. Use of this electrical load calculation estimate methodology is at the user's risk and carries no implied guarantee of accuracy. Users of this methodology and these forms are advised to seek professional assistance in determining the electrical capacity of a service panel.

(Date)